



INSPECTION REPORT

**UNIVERSITY OF NORTH
CAROLINA
@ CHAPEL HILL**

Customer ID: 826

Certificate: 55-R-0004

Site: 001

**UNIVERSITY OF NC @ CHAPEL
HILL**

Inspection

Type: ROUTINE INSPECTION

Date: DEC-04-2007

**1100 BIOINFORMATICS BLDG
CHAPEL HILL, NC 27599**

3.2 (d)

INDOOR HOUSING FACILITIES.

Interior surfaces. The floors and walls of indoor housing facilities, and any other surfaces in contact with the animals, must be impervious to moisture. The ceilings of indoor housing facilities must be impervious to moisture or be replaceable.

****At Hillsborough facility, multiple walls have areas of blistering, peeling paint. This problem was identified by IACUC on last inspection and arrangements have been made with servicing company at this leased facility to repaint affected rooms. Complete correction by February 1, 2008.**

Prepared By:


F BINKLEY, D V M, USDA, APHIS, Animal Care

Title: VETERINARY MEDICAL OFFICER , Inspector ID: 1020

Date:

DEC-05-2007

Received By:

Date:

DEC-05-2007

Title: